



**203 Ashmore Road
Benowa QLD 4217**

**Water Supply and Sewer
Network Capacity Assessment**

FINAL Report V1 - 23 May, 2025



H2One Pty Ltd

Water, Sewer and Stormwater Engineering Specialists

H2One Pty Ltd

ABN 20 130 354 764

P 07 5463 9538

E info@H2One.com.au

W h2one.com.au

| Reviewed by RPEQ | Reg. No. | Signed | Date |
|------------------|----------|--|--------------|
| Joshua May | 18064 |  | 23 May, 2025 |

| Version | Date | Author | Reviewer |
|------------|--------------|--------------|----------|
| DRAFT - V1 | 19 May, 2025 | J Meesamphan | J May |
| FINAL - V1 | 23 May, 2025 | J Meesamphan | J May |
| | | | |
| | | | |

Copyright in the whole and every part of this document belongs to H2One Pty Ltd and may not be used, sold, transferred, copied or reproduced in whole or in part in any manner or form or in or on any media to any person without the prior written approval of H2One Pty Ltd.

TABLE OF CONTENTS

| | | |
|-------|--|----|
| 1 | INTRODUCTION..... | 2 |
| 1.1 | Background | 2 |
| 1.2 | Objectives..... | 2 |
| 1.3 | Sewerage Strategy | 2 |
| 1.4 | Water Supply Zone..... | 2 |
| 1.5 | Demand Assessment..... | 3 |
| 2 | METHODOLOGY | 5 |
| 2.1 | Design Standards..... | 5 |
| 2.2 | Sewerage Network Assessment..... | 6 |
| 2.3 | Water Supply Network Assessment..... | 6 |
| 3 | RESULTS | 8 |
| 3.1 | Sewerage Network Assessment..... | 8 |
| 3.1.1 | Pumps..... | 8 |
| 3.1.2 | Wet Wells | 8 |
| 3.1.3 | Gravity Mains | 8 |
| 3.1.4 | Emergency Storage..... | 8 |
| 3.2 | Water Supply Network Assessment..... | 9 |
| 3.2.1 | Standard Flow..... | 9 |
| 3.2.2 | Fire Flow | 10 |
| 4 | CONCLUSION..... | 13 |
| 5 | REFERENCE LIST | 14 |
| 6 | APPENDICES..... | 15 |
| | Appendix 1. Development layout plan and concept water/sewer service strategy | 16 |
| | Appendix 2. Development site and SPS A16 sewer catchment..... | 17 |
| | Appendix 3. Development site and Benowa Rd DMA..... | 18 |
| | Appendix 4. Pump capacity assessment results..... | 19 |
| | Appendix 5. Operational storage capacity assessment results | 21 |
| | Appendix 6. Recommended sewer gravity main upgrade | 22 |
| | Appendix 7. Gravity main flow depth capacity assessment results | 23 |
| | Appendix 8. Emergency storage capacity assessment results | 25 |
| | Appendix 9. Water supply standard flow and fire flow modelling results | 26 |

1 INTRODUCTION

1.1 Background

A mixed-use development, at 203 Ashmore Rd, Benowa QLD, is currently in the planning phase of the Development Application (DA) process. The real property description for this site is Lot 822 on RP839746, with the proposed land-use type and density as per the following. Refer to Appendix 1 for the development layout plans.

- 306 x 2 bedroom apartments
- 91 x 3 bedroom apartments
- 13,000 m² Gross Floor Area (GFA) of retail and commercial space

To support the DA, City of Gold Coast (CoGC) requested a water supply and sewerage network capacity assessment to determine if the site's additional loading will impact system performance and trigger the need for infrastructure upgrades. H2One Pty Ltd was engaged to undertake the assessment in accordance with CoGC's requirements; *"South East Queensland Water Supply and Sewerage Design and Construction Code"* (2020) and the *"Water and Sewerage Connections Policy Procedure"* (2018). The results of the investigation are presented in this report.

1.2 Objectives

The objectives of the project were as follows.

1. Assess the capacity of existing gravity mains, rising mains, pumps, wet wells and emergency storage for the relevant sewer catchment; Sewer Pump Station (SPS) A16.
2. Assess standard flow and fire flow capacity of the relevant water supply network; Benowa Road District Metered Area (DMA).
3. Determine infrastructure upgrades necessary to achieve CoGC's minimum design standards, where system performance failures have occurred due to the additional loading of the new development, and;
4. Prepare a network capacity assessment report.

1.3 Sewerage Strategy

The development site is located within the SPS A16 sewerage catchment, with the proposed connection located on the existing diameter nominal (DN) 150 mm gravity main adjacent to the eastern property boundary. The development's sewage outfall will continue east via DN225 and DN300 trunk gravity pipes, discharging to SPS A16. This pump station operates with duty-assist pumps that inject into a shared pressure main that is ultimately serviced by the Coombabah Sewage Treatment Plant (STP).

As per CoGC's Local Government Infrastructure Plan (LGIP) demand model, SPS A16 is estimated to currently service 3,400 EP, which is projected to increase to a maximum of 5,230 EP at the Ultimate planning horizon (2066).

Refer to Appendix 1 and Appendix 2 for an overview of the site location and relevant service strategy.

1.4 Water Supply Zone

The development site is located within the Benowa Road DMA, which is serviced by a flow modulated Pressure Reducing Valve (PRV) with a maximum residual pressure setting of 40 m. The DMA is serviced

by the Molendinar LLZ water tanks (MO4, MO5 and MO6), via a network of DN965, DN750, and DN300 trunk pipes. The proposed connection point will be located on the existing DN150 main along Carrara Street.

The pipe chainage from the Molendinar water tanks to the proposed connection point is estimated at 5.5 km. The Molendinar tanks are positioned at an RL of 68.4 m AHD and currently services 175,000 EP, which is estimated to increase to a maximum of 509,000 EP at the ultimate planning horizon (2066).

Refer to Appendix 3 for an overview of site location and relevant service strategy.

1.5 Demand Assessment

A demand assessment of the development was undertaken to determine the approximate potable water and sewage demands attributed to the proposed land-use type and density. This was calculated using CoGC's adopted Equivalent Person (EP) unit rates and average "per capita" demands for potable water @ 220L/EP/day, and sewage @ 200 L/EP/day and 180 L/EP/day for the 2021-2041 and 2066 planning horizons, respectively.

Table 1. Estimated water supply and sewage loading from the proposed development

| Site Land Use and Density | Demand Rate | EP | Water (kL/day) | Sewage (kL/day) |
|---|----------------------------|--------------|----------------|-----------------|
| 306 x 2 bedroom res. apt. | 1.76 EP/Apt | 538.6 | 118.5 | 107.7 |
| 91 x 3+ bedroom res. apt. | 2.51 EP/Apt | 228.4 | 50.3 | 45.7 |
| 13,000 m ² (GFA) retail/com. | 1.68 EP/100 m ² | 218.4 | 48.0 | 43.7 |
| TOTAL | | 985.4 | 216.8 | 197.1 |

For the post-development scenarios of the water supply and sewer network assessment, CoGC's LGIP site demands were removed from the existing model and replaced with the demands presented in Table 1 above. These figures were provided by CoGC and are presented in Table 2 below.

Table 2. CoGC's LGIP demands (EP) removed from the water and sewer models @ post-develop.

| Address | Node ID | 2021 | 2026 | 2031 | 2036 | 2041 | 2066 |
|------------------------|------------------------------|-------|-------|-------|-------|-------|-------|
| 203 Ashmore Rd, Benowa | SEMH_A016_9000155261 (sewer) | 152.1 | 168.8 | 185.6 | 202.3 | 219.1 | 266.1 |
| | MO_11100069906_WTFT (water) | 170.9 | 189.7 | 208.5 | 227.3 | 246.1 | 298.9 |

Prior to the study, the demands presented in Tables 3 and 4 below were introduced to the hydraulic models to account for planned development within the local network. These figures were advised by CoGC and consider existing LGIP demands already present in the model.

Table 3. Development demands (EP) updated in the sewer model, prior to the hydraulic assessment

| Address | Sewer Node ID | 2021 (EP) | 2066 (EP) |
|--------------------------|----------------------|-----------|-----------|
| 60 Allchurch Ave, Benowa | SEMH_A016_9000155261 | 241.9 | 236.5 |

Table 4. Development demands (EP) updated in the water supply model, prior to the hydraulic assessment

| Address | Node ID | 2021 | 2026 | 2031 | 2036 | 2041 | 2066 | Water Pattern |
|--|---|---------|---------|---------|---------|---------|---------|---------------|
| 60, 64 SeaWorld Dr, Main Beach | MO_111002267 34_WTFT | 1,077.2 | 1,058.0 | 1,039.8 | 1,021.6 | 1,002.4 | 822.5 | RMF_1 |
| 6, 8, 10, 16 Frederick St & 18 Garfield Tce, Surfers Paradise | MO_111004403 15_WTHY | 348.1 | 341.8 | 335.6 | 326.2 | 316.8 | 316.8 | RMF_1 |
| 59 Garfield Tce, Surfers Paradise | MO_111004446 80_WTFT | 110.8 | 110.6 | 110.4 | 110.2 | 110.0 | 7.7 | RMF_1 |
| 21 Oak Ave & 11 Birt Ave, Surfers Paradise | MO_56918PIPE_ 11100441131_N ODE | 119.8 | 119.8 | 119.7 | 119.5 | 119.4 | 31.5 | RMF_1 |
| 82-92 Ferny Ave, Surfers Paradise | MO_111002411 54_WTFT | 352.7 | 55.1 | 51.2 | 45.5 | 39.7 | 4.9 | RMF_1 |
| 106-112 Ferny Ave, 3-19 Pine Ave, 2-18 Norfolk Ave, Surfers Paradise | MO_111004395 94_WTHY, MO_111002034 69_WTHY | 1,662.2 | 195.5 | 175.9 | 146.5 | 117.1 | 117.1 | RMF_1 |
| 5-7 Peninsular Dr, Surfers Paradise | MO_111004415 40_WTHY | 123.0 | 123.0 | 123.0 | 35.0 | 34.9 | 34.9 | RMF_1 |
| 27 Thornton St, 26 Vista St, 2949-2957 Surfers Paradise Blvd, Surfers Paradise | MO_111000438 86_WTHY | 327.6 | 37.2 | 32.8 | 26.3 | 19.8 | 19.8 | RMF_1 |
| 3550-3552 Main Beach Pde, Main Beach | MO_111000619 09_WTFT | 165.2 | 165.1 | 165.0 | 165.0 | 164.9 | 47.2 | RMF_1 |
| 47-49 Pacific St, Main Beach | MO_111003292 37_WTVL | 52.2 | 52.0 | 51.9 | 51.8 | 51.5 | 0.0 | RMF_1 |
| 24-26 Woodroffe Ave, Main Beach | MO_111003060 43_WTHY | 61.9 | 61.8 | 61.8 | 61.7 | 61.6 | 0.0 | RMF_1 |
| 84-88 The Esplanade and 3271-3275 Surfers Paradise Blvd, Surfers Paradise | MO_111000535 99_WTHY, MO_111004681 21_WTFT | 386.1 | 374.7 | 363.3 | 346.2 | 329.1 | 329.1 | RMF_1 |
| 3513 Main Beach Pde, Main Beach | MO_111003073 34_WTFT | 36.5 | 36.4 | 36.4 | 36.3 | 36.2 | 35.9 | RMF_1 |
| 3547-3549 Main Beach Pde, Main Beach | MO_111002034 56_WTHY | 296.0 | 295.9 | 295.9 | 295.8 | 189.8 | 94.2 | RMF_1 |
| 3496 Main Beach Pde, Main Beach | MO_111000617 61_WTHY | 180.5 | 178.9 | 178.1 | 177.3 | 175.6 | 175.6 | RMF_1 |
| 152, 154, 158, 162 Esplanade, Surfers Paradise | MO_111004396 35_WTHY | 167.4 | 159.2 | 151.0 | 138.7 | 126.3 | 126.3 | RMF_1 |
| 3 Pacific St, Main Beach | MO_111002371 92_WTVL | 205.9 | 119.6 | 118.9 | 118.2 | 116.8 | 116.8 | RMF_1 |
| 3155-3173 Surfers Paradise Blvd & 24-26 Orchid Ave, Surfers Paradise | MO_111004677 94_WTFT, MO_111004437 91_WTFT | 1,430.0 | 1,430.0 | 1,430.0 | 1,430.0 | 1,430.0 | 1,430.0 | RMF_1 |

Note it is understood that the above development may still be undergoing assessment with CoGC's approval yet to be provided. As a result, consideration of relevant demands is indicative only.

2 METHODOLOGY

2.1 Design Standards

The design standards adopted for the hydraulic assessment were based on the “*South East Queensland Water Supply and Sewerage Design and Construction Code*” (2020), with exception to the maximum depth of gravity pipe flow at 1.0 m freeboard. This requirement is merely a standard industry practice adopted by water authorities in South-east Queensland, and is not a specific design standard from either the SEQ Code or Water Service Association of Australia (WSAA) Sewerage Code. A summary of the relevant design provisions utilised for the project is as follows.

Table 5. SEQ Code provisions relevant to the study

| | Provision | Specification |
|--------------|--|---|
| Sewerage | ET to EP conversion factor | 2.79 |
| | Average Dry Weather Flow (ADWF) | 200 L/EP/day |
| | Peak Wet Weather Flow (PWWF) | 5 x ADWF |
| | Single pump capacity | $C1 \times \text{ADWF (L/s)}$ where; $C1 = 3.5$ to 5.0 $C1 = 15 \times (\text{EP})^{-0.1587}$ |
| | Pump station operational storage (m^3) | $0.9 \times Q / N$ where; $Q = \text{Single pump capacity (L/s)}$ $N = \text{Number of pump starts per hour, where}$ $N = 12$ for duty pump motor < 100 kW $N = 8$ for duty pump motor $100 - 200$ kW $N = 5$ for duty pump motor > 200 kW |
| | Pump station emergency storage (m^3) | 4 hours ADWF |
| | Total pump station capacity (L/s) | PWWF |
| | Maximum depth of gravity flow (proposed system) | 75% pipe diameter |
| | Maximum depth of gravity flow (existing system) | 1.0 m below manhole level |
| Water Supply | Maximum pressure main flow velocity | 3.0 m/s |
| | ET to EP conversion factor | 2.79 |
| | Average Day Demand | 220 L/EP/day |
| | Maximum pipe velocity (m/s) | 2.5 m/s |
| | Standard flow minimum network pressure and background demand | 22m at the property boundary at PH demand |
| | Residential fire flow minimum network pressure and background demand | 12m at 2/3 PH demand Positive pressure at PH demand Reservoir at Minimum Operating Level (15%) |
| | Commercial fire flow minimum network pressure and background demand | 12m at PH demand |
| | Fire flows | Residential - 15L/s Commercial/industrial - 30L/s |

2.2 Sewerage Network Assessment

The methodology adopted for the hydraulic analysis of the sewer network is as follows.

1. CoGC's latest LGIP InfoWater SWMM sewerage network model was adopted for the analysis ("CO_WSSIP_2019"). The site's estimated demand was placed into the model on manhole "SEMH_A016_9000155261", in addition to the demand changes described in Section 1.5 of this report. Refer to Appendix 2 for the location of the demand manhole.
2. The pump capacity of SPS A16 was assessed by running the model at PWWF and determining if wet well levels operated within the stand-by pump start/stop settings. This method was adopted as SPS A16 injects into a shared pressure system and was considered the most suitable option to assess the pump station's ability to manage inflow.

If the pump station could not maintain acceptable levels and surcharging occurred, pump and/or rising main capacity upgrades were investigated until design standards were achieved. Impact to pump stations injecting against SPS A16 were also assessed to determine if they were negatively affected by changes to pump operation and/or upgrades.

3. The wet well operational storage of SPS A16 was subsequently evaluated by comparing the required operational storage capacity, post-development, against wet well volumes between duty pump start/stop levels.

If the wet well's operational storage volume was above the minimum requirement, compliance was achieved. If it was below the minimum requirement, pump and pressure main upgrades were investigated until design standards were achieved.

4. The flow depth of gravity mains was assessed from the proposed connection point to SPS A16, at pre- and post-development PWWF. To avoid surcharging from unrelated issues downstream, pumps were deactivated from the model and gravity mains discharged directly to a wet well outlet.

If flow depths could not be maintained within CoGC specifications, pipe augmentations were investigated until design standards were achieved.

5. The emergency storage of the SPS A16 catchment was assessed by determining the available ADWF network volume between the overflow level (RL 2.108 m AHD - 0.3 m) and pump duty start level (RL 0.04 m AHD). This was achieved by calculating the "empty" volume of the network and subtracting the post-development ADWF volume already present in the network.

The available emergency storage was compared against the 4 hour ADWF requirement. If the available storage was above the minimum requirement, compliance was achieved. If it was below the minimum requirement, compliance was not achieved and storage augmentations were investigated.

6. Modelling results were verified and findings reported.

2.3 Water Supply Network Assessment

The methodology adopted for the water supply network analysis is as follows.

1. CoGC's latest InfoWater LGIP hydraulic model was adopted for the water supply analysis ("Northern v102_WSSIP_2019"). The site's estimated demand and diurnal pattern were placed into the model on node "MO_11100069906_WTFT". LGIP demands were also introduced/removed as per Section 1.5 of this report. Refer to Appendix 3 for location of the demand node.

2. For all planning horizons, a detailed standard flow hydraulic analysis was undertaken on the supply tanks, property connection point/s and surrounding network. This was based on a 3 x consecutive Maximum Day (MD) demand scenario at pre- and post-development. Any deficiencies in the network were investigated and appropriate solutions determined.
3. The hydrants directly servicing the site was allocated 30 L/s for both pre- and post-development scenarios. A detailed fire flow hydraulic analysis was undertaken on the local network, based on a 1 x MD demand event. Any deficiencies in the network were investigated and appropriate solutions determined.
4. Modelling results were verified and findings reported.

3 RESULTS

3.1 Sewerage Network Assessment

3.1.1 Pumps

A pump capacity assessment was undertaken on SPS A16, as per the methodology described in Section 2.2 of this report. The analysis identified that the combined pump capacity was sufficient to incorporate the development's sewage loading, across all planning horizons. No pump capacity upgrades are therefore required.

Refer to Appendix 4 for detailed modelling results of the pump capacity assessment.

3.1.2 Wet Wells

An assessment on the operational storage capacity of the SPS A16 wet well was undertaken with the inclusion of the development's estimated loading. Table 6 below shows a summary of results and Appendix 5 provides detailed calculations.

Table 6. Operational storage capacity results (post-development)

| Planning Horizon | Storage Available (kL) | Storage Required (kL) | Difference (kL) |
|------------------|------------------------|-----------------------|-----------------|
| 2021 | 10.23 | 3.07 | +7.16 |
| 2066 | 10.23 | 3.63 | +6.60 |

The above table demonstrates there is sufficient operational storage to incorporate the additional site loading, across all planning horizons. No wet well capacity upgrades are therefore required to service the proposed development.

3.1.3 Gravity Mains

As per the methodology described in Section 2.2 of this report, gravity pipe flow depths were assessed against the CoGC's minimum requirement (1.0 m below manhole level), from site connection to SPS A16. The hydraulic analysis determined that the downstream gravity main system has insufficient capacity to service the proposed development within 1.0 m freeboard, across all planning horizons.

However, the identified flow depths remained within pipe and no overflows occurred. A potential pipe upgrade should be reviewed by CoGC as to the need and/or timing of construction. If required, this would consist of 270 m of DN150 pipework being upgraded to DN225.

Refer to Appendix 6 for a concept layout of the proposed pipe upgrade and Appendix 7 for detailed modelling results.

3.1.4 Emergency Storage

An emergency storage capacity assessment was undertaken on the SPS A16 catchment, with the inclusion of the additional ADWF attributed to the proposed development (1.9 L/s). Table 7 below shows a summary of results and Appendix 8 shows detailed calculations.

Table 7. Emergency storage capacity results (post-development)

| Planning Horizon | Storage Available (kL) | Storage Required (kL) | Difference (kL) |
|------------------|------------------------|-----------------------|-----------------|
| 2021 | 115.1 | 102.8 | +12.4 |
| 2031 | 113.9 | 111.3 | +2.7 |
| 2036 | 113.7 | 114.2 | -0.4 |
| 2041 | 113.4 | 117.1 | -3.6 |
| 2066 | 113.0 | 129.1 | -16.1 |

The results in the above table demonstrate that there is sufficient emergency storage available to incorporate the additional site loading, at the 2021 to 2031 planning horizons. For the 2036 to 2066 planning horizons however, insufficient emergency storage was identified, triggered by the development's additional sewage loading. A 16.1 kL storage upgrade will therefore be required from the 2036 planning horizon, in order to achieve CoGC's minimum storage requirement of 4-hours ADWF.

3.2 Water Supply Network Assessment

3.2.1 Standard Flow

As per the methodology described in Section 2.3 of this report, a detailed standard flow network analysis was undertaken on all planning horizons with the inclusion of the estimated development demands. A summary of results is presented below in Table 8.

Table 8. Standard flow network modelling results (post-development)

| Provision | Planning Horizon | | | | | |
|---|-------------------------|------|------|------|------|------|
| | 2021 | 2026 | 2031 | 2036 | 2041 | 2066 |
| Conn. (MO_11100069906_WTFT) min. pressure (m) | 62.4 | 62.4 | 60.9 | 59.4 | 57.0 | 50.1 |
| Network min. pressure (m) | 38.8 | 38.5 | 36.9 | 35.3 | 33.0 | 27.3 |
| Network min. pressure node ID | MO_11100320898_WTFT | | | | | |
| Network no. failures | 0 | 0 | 0 | 0 | 0 | 0 |
| Tank min. water level (%) | 80% | 82% | 77% | 72% | 62% | 48% |
| Max. pipe velocity (m/s) | 0.8 | 1.0 | 1.0 | 1.0 | 1.0 | 1.0 |
| Network max. velocity ID | MO_9546PIPE_11100057795 | | | | | |
| Network no. failures | 0 | 0 | 0 | 0 | 0 | 0 |

The above results demonstrate that the network performed within CoGC's minimum standard flow design standards, across all planning horizons. No infrastructure upgrades are therefore required to service the proposed development.

Refer to Appendix 9 for modelling results at pre- and post-development.

3.2.2 Fire Flow

As per the methodology described in Section 2.3 of this report, a detailed fire flow network analysis was undertaken on all planning horizons with the inclusion of estimated development demands. A summary of results is presented below in Table 9.

Table 9. Fire flow network modelling results (post-development)

| | | Planning Horizon | | | | | |
|---------------|---|---------------------|------|------|------|------|------|
| Scenario | | 2021 | 2026 | 2031 | 2036 | 2041 | 2066 |
| Peak Hour | Site hydrant (<i>MO_11100075453_WTHY</i>) min. pressure (m) | 56.2 | 52.5 | 50.6 | 49.1 | 47.5 | 43.3 |
| | Network hydrants min. pressure (m) | 12.2 | 5.0 | 2.8 | 1.3 | -0.4 | -3.1 |
| | Network hydrant min. pressure node ID | MO_11100067480_WTHY | | | | | |
| | Network hydrants no. failures | 0 | 0 | 1 | 1 | 2 | 2 |
| 2/3 Peak Hour | Site hydrant (<i>DEM_NODE_HY</i>) min. pressure (m) | 60.7 | 59.0 | 57.8 | 56.6 | 55.0 | 51.2 |
| | Network hydrants min. pressure (m) | 16.4 | 13.8 | 13.6 | 12.4 | 10.8 | 7.9 |
| | Network hydrant min. pressure node ID | MO_11100067480_WTHY | | | | | |
| | Network hydrants no. failures | 0 | 0 | 0 | 0 | 1 | 1 |

Note: Results based on supply reservoirs operating at MOL (15%), peak hour at 7 am and 2/3 peak hour at 3.30 pm.

The above results demonstrate that the network performed within CoGC's minimum fire flow design standards, with exception to a small number of peak hour and 2/3 peak hour failures from the 2031 planning horizon. Further investigation identified that these failures occurred due to a couple of model discrepancies, i.e. a misallocation of a 30 L/s fire flow within a residential area, and a DN100 cross-connection that has yet to be updated in CoGC's model. Refer to Figures 1 and 2 below for further details.



Figure 1. Residential node incorrectly allocated with 30 L/s fire flow (Source: CoGC's online mapping tool)



Figure 2. DN100 cross-connection not present in CoGC's model (Source: CoGC's online mapping tool)

With the resolution of the above model issues, the minimum fire flow pressure were determined to be 16.5 m @ 15 L/s (2/3 PH) and 26.1 m @ 30 L/s (PH). This is in compliance with CoGC's minimum design standards, therefore no water supply infrastructure upgrades are required to service the proposed development.

Refer to Appendix 9 for the modelling results at pre- and post-development, prior to the implementation of the model updates described above.

4 CONCLUSION

A mixed-use development, at 203 Ashmore Rd, Benowa QLD, is currently in the planning phase of the Development Application (DA) process. The real property description for this site is Lot 822 on RP839746, with the proposed land-use type and density as per the following.

- 306 x 2 bedroom apartments
- 91 x 3 bedroom apartments
- 13,000 m² Gross Floor Area (GFA) of retail and commercial space

To support the DA, City of Gold Coast (CoGC) requested a water supply and sewerage network capacity assessment to determine if the site's additional loading (985 EP) will impact system performance and trigger the need for infrastructure upgrades. H2One Pty Ltd was engaged to undertake the assessment in accordance with CoGC's requirements; *"South East Queensland Water Supply and Sewerage Design and Construction Code"* (2020) and the *"Water and Sewerage Connections Policy Procedure"* (2018).

The hydraulic analysis determined that, theoretically, there was sufficient capacity in the water supply network to incorporate the development loading, across all planning horizons. For the sewer network however, the following capacity shortfalls were identified in servicing the proposed development.

- The gravity pipe system downstream of the connection point operated with a flow depth above 1.0 m from ground level, across all planning horizons. However, the maximum flow depth remained within pipe and no overflows occurred. The potential of a pipe upgrade should be reviewed by CoGC as to the need and/or timing of construction. If required, this would consist of 270 m of DN150 pipework being upgraded to DN225, downstream of the connection point.
- The SPS A16 catchment presented insufficient emergency storage capacity to service the proposed development, prior to the 2036 planning horizon. The installation of a 16.1 kL emergency storage upgrade will likely be required to achieve 4 hours of Average Dry Weather Flow (ADWF) storage.

It is recommended that CoGC approves the proposed water supply and sewer service strategies for the proposed development at 203 Ashmore Rd, Benowa QLD, with consideration to the infrastructure requirements identified in this report.

Detailed modelling results, calculations and system plans can be observed in Appendices 1 through 9.

5 REFERENCE LIST

CoGC. (2020). *SEQ Water Supply and Sewerage Design and Construction Code*. Gold Coast: City of Gold Coast

CoGC. (2018). *Water and Sewerage Connections Policy Procedure*. Gold Coast: City of Gold Coast

6 APPENDICES

Appendix 1. Development layout plan and concept water/sewer service strategy

BENOWA GARDENS MASTER PLAN

SITE INFORMATION


ADDRESS 203 ASHMORE ROAD
BENOWA QLD 4217

RPD LOT/DP: RP839746

SITE AREA 17,658m²

LEGEND

- RETAIL
- STAFF BICYCLE PARKING
- COMMERCIAL
- RESIDENTIAL
- VISITOR BICYCLE PARKING
- COMMUNITY OUTDOOR
- REFUSE
- PERIMETER USE



APARTMENT TYPES

| | LEVELS | 2 x BED | 3 x BED | TOTAL |
|------------------|----------------------|---------|---------|-------|
| CARRARA TOWER | PER LEVEL (x 9) | 12 | 3 | 15 |
| | TOTAL PER TOWER | 108 | 27 | 135 |
| BENOWA TOWER | PER LEVEL (x 8) | 12 | 4 | 16 |
| | TOTAL PER TOWER | 96 | 32 | 128 |
| ASHMORE TOWER | PER LEVEL (x 7) | 14 | 4 | 18 |
| | PER HALF LEVEL (x 1) | 4 | 4 | 8 |
| | TOTAL PER TOWER | 102 | 32 | 134 |
| TOTAL APARTMENTS | | 306 | 91 | 397 |

PERIMETER USE: 8,400m²

| | SHORT STAY ACCOMMODATION | RESIDENTIAL 1 BED | HEALTH CARE |
|-----------------------------|----------------------------------|----------------------|-------------------------|
| BASEMENT 2 | 130m ² TUA (LOBBY) | - | - |
| BASEMENT 1 | 11 | - | 1,200m ² TUA |
| GROUND (SHOPPING CENTRE) | 15 | - | 1,200m ² TUA |
| CARRARA LEVEL 1 | 15 | - | 1,200m ² TUA |
| CARRARA LEVEL 2 | - | 22 | 2,400m ² TUA |
| CARRARA LEVEL 3 | - | 22 | 2,400m ² TUA |
| TOTAL | 41 | 44 | 8,400m ² |

CARPARKING

| | |
|-----------------------|----------|
| RETAIL | |
| BASEMENT 3 | 190 CARS |
| BASEMENT 2 | 260 CARS |
| BASEMENT 1 | 250 CARS |
| TOTAL RETAIL CARPARKS | 700 CARS |

| | |
|----------------------------|----------|
| RESIDENTIAL | |
| LEVEL 2 | 220 CARS |
| LEVEL 3 | 270 CARS |
| TOTAL RESIDENTIAL CARPARKS | 490 CARS |

| | |
|------------------------------|----------|
| PERIMETER USE | |
| BASEMENT 3 | 270 CARS |
| TOTAL PERIMETER USE CARPARKS | 270 CARS |

| | |
|----------------|-------|
| TOTAL CARPARKS | 1,460 |
|----------------|-------|

BICYCLE PARKING

| | |
|--------------------|------------|
| STAFF | |
| BASEMENT 2 | 100 SPACES |
| TOTAL STAFF SPACES | 100 SPACES |

| | |
|--------------------|------------|
| VISITOR | |
| BASEMENT 2 | 86 SPACES |
| BASEMENT 1 | 114 SPACES |
| TOTAL STAFF SPACES | 200 SPACES |

| | |
|----------------------|-----|
| TOTAL BICYCLE SPACES | 300 |
|----------------------|-----|

AREA CALCULATIONS


| | |
|--------------------------|----------------------|
| RETAIL AREA | |
| SUPERMARKET | 4,000m ² |
| SPECIALTY SHOPS: | 6,000m ² |
| RETAIL BASEMENT 2 LEVEL: | 700m ² |
| RETAIL BASEMENT 1 LEVEL: | 300m ² |
| SHOPPING CENTRE LEVEL: | 5,000m ² |
| TOTAL RETAIL | 10,000m ² |

| | |
|------------------|---------------------|
| COMMERCIAL AREA | |
| LEVEL 1: | 2,500m ² |
| LEVEL 2: | 500m ² |
| TOTAL COMMERCIAL | 3,000m ² |


SITE PLAN

1:1000


FLOOR PLAN-SHOPPING CENTRE




Appendix 2. Development site and SPS A16 sewer catchment



Appendix 3. Development site and Benowa Rd DMA



INSET 1



LEGEND

Trunk main

Retic main

PRV

Model node

Demand node

Benowa Rd DMA


Development site

Property boundary


| | | | | | | | | | | | | |
|--|--|---------------------------|--|--|--|--|--|------------------------|--|---|--|--|
| <div><div>H2ONE</div><div><div>Important Notice!</div><div>This map is not a precise survey document. Accurate locations can only be determined by a survey on the ground.</div><div>H2One Pty Ltd gives no warranty in relation to the data (including accuracy, reliability, completeness or suitability) and accepts no liability (including without limitation, liability in negligence) for any loss, damage or costs (including consequential damage) relating to any use of the data.</div></div></div> | <div><div>H2One Pty Ltd</div><div>PO Box 23</div><div>KALBAR QLD 4309</div><div>P: 07 5463 9538</div><div>E: Info@H2One.com.au</div><div>W: h2one.com.au</div></div> | DESIGNED: J Meesamphan | | NOTE: DESIGN NOT TO BE AMENDED WITHOUT H2ONE PTY LTD ACCEPTANCE | | DATUM: HORIZ: MGA94 (ZONE 56) | | H2ONE REFERENCES | | <div><div>203 Ashmore Rd</div><div>Benowa QLD 4217</div><div>Water Supply and Sewerage</div><div>Network Capacity Assessment</div><div>Appendix 3. Development site</div><div>and Benowa Rd DMA</div></div> | ORIGINAL ISSUE DATE: MAY, 2025 | |
| | | DRAWN: J Meesamphan | | | | HEIGHT: AHD | | PROJECT NO: 2505699 | | | DATE SCANNED: | |
| | | CHECKED: J May | | | | SCALE: <div><div>0</div><div>225</div><div>450</div><div>Metres</div></div> | | FILE REFERENCE: | | | | |
| | | APPROVED: J May | | | | SURVEYED BY / DATE: | | CAD FILE: | | | CITY OF GOLD COAST PO BOX 5042, GCMC QLD 9729 | |
| | | CLIENT PM: | | A | | ORIGINAL ISSUE - 19 MAY, 2025 | | | | | DRG No: | |
| | | H2ONE PM: J May | | No. | | REVISION | | APPROVED | | | REV: | |

Appendix 4. Pump capacity assessment results


2021, SPS A016




2021, Injection System



2066, SPS A016



2066, Injection System



Appendix 5. Operational storage capacity assessment results


| | | 2021 (Post-develop.) | 2066 (Post-develop.) |
|--------------------------------------|---------------------|-------------------------|-------------------------|
| Single Pump Capacity Required | C1 | 3.95 | 3.75 |
| | ADWF (L/s) | 10.35 | 12.89 |
| | Q (L/s) | 40.90 | 48.37 |
| Storage Capacity Required | Pump Setup | Duty/Assist | Duty/Assist |
| | Duty Head (m) | NA | NA |
| | Pump Efficiency (%) | NA | NA |
| | Duty Power (kW) | <100.00 | <100.00 |
| | No. pump starts (n) | 12.00 | 12.00 |
| | Volume (kL) | 3.07 | 3.63 |
| Storage Capacity Available | Duty Start (m) | 2.31 | 2.31 |
| | Duty Stop (m) | 0.90 | 0.90 |
| | Duty Height (m) | 1.41 | 1.41 |
| | WW Diam. (m) | 3.04 | 3.04 |
| | Volume (kL) | 10.23 | 10.23 |
| OUTCOME | Difference (kL) | +7.16 | +6.60 |
| | Pass / Fail | Pass | Pass |

Note: Wet well and pump details were sourced from the CoGC's LGIP hydraulic model.


Appendix 6. Recommended sewer gravity main upgrade

Appendix 7. Gravity main flow depth capacity assessment results


2021, Pre-development



2021, Post-development




2026, Post-development




2066, Pre-development

Profile with Maximum Data of Links GM_A016_9000101222L01, GM_A016_9000101219L01, ..., GM_A016_90002340




2066, Post-development

Profile with Maximum Data of Links GM_A016_9000101222L01, GM_A016_9000101219L01, ..., GM_A016_90002340



2066, Post-development + DN225 upgrade

Profile with Maximum Data of Links GM_A016_9000101222L01, GM_A016_9000101219L01, ..., GM_A016_90002340



Appendix 8. Emergency storage capacity assessment results

| | Pipe ID | US IL (m) | DS IL (m) | Length (m) | Length Below OF (m) | Slope (%) | Diam. (m) | Radius (m) | d/D (%) | Pipe Flow Depth (m) | Pipe Wetted Area (m) | Empty Vol. Below OF (m3) | ADWF Vol. Below OF (m3) | ES Vol. Avail. (m3) |
|--------------------|-----------------------|-----------|-----------|------------|---------------------|-----------|-----------|------------|---------|---------------------|----------------------|--------------------------|-------------------------|---------------------|
| 2021 Pre-develop. | GM_A016_9000100916L01 | 0.62 | 0.43 | 59.2 | 59.2 | 0.0033 | 0.225 | 0.11 | 15.0% | 0.034 | 0.0037 | 2.4 | 0.2 | 2.1 |
| | GM_A016_9000101219L01 | 2.89 | 2.70 | 41.6 | - 195.2 | 0.0046 | 0.150 | 0.08 | 15.1% | 0.023 | 0.0017 | - 3.4 | - 0.3 | - |
| | GM_A016_9000101222L01 | 3.59 | 2.89 | 58.5 | - 90.4 | 0.0120 | 0.150 | 0.08 | 14.2% | 0.021 | 0.0015 | - 1.6 | - 0.1 | - |
| | GM_A016_9000101241L01 | 0.27 | 0.19 | 33.5 | 33.5 | 0.0024 | 0.225 | 0.11 | 21.0% | 0.047 | 0.0061 | 1.3 | 0.2 | 1.1 |
| | GM_A016_9000101247L01 | 0.86 | 0.62 | 70.0 | 70.0 | 0.0033 | 0.225 | 0.11 | 14.0% | 0.032 | 0.0034 | 2.8 | 0.2 | 2.5 |
| | GM_A016_9000154951L01 | 0.35 | 0.33 | 92.7 | 92.7 | 0.0002 | 0.300 | 0.15 | 18.0% | 0.054 | 0.0086 | 6.5 | 0.8 | 5.8 |
| | GM_A016_9000155308L01 | 0.15 | 0.12 | 19.6 | 19.6 | 0.0016 | 0.300 | 0.15 | 22.4% | 0.067 | 0.0118 | 1.4 | 0.2 | 1.2 |
| | GM_A016_9000233697L01 | 0.43 | 0.35 | 23.3 | 23.3 | 0.0033 | 0.300 | 0.15 | 16.0% | 0.048 | 0.0073 | 1.6 | 0.2 | 1.5 |
| | GM_A016_9000233921L01 | 0.33 | 0.31 | 6.5 | 6.5 | 0.0031 | 0.300 | 0.15 | 13.0% | 0.039 | 0.0054 | 0.5 | 0.0 | 0.4 |
| | GM_A016_9000233993L01 | 2.69 | 2.22 | 64.0 | - 56.1 | 0.0073 | 0.150 | 0.08 | 14.9% | 0.022 | 0.0016 | - 1.0 | - 0.1 | - |
| | GM_A016_9000234021L01 | 2.09 | 1.74 | 47.2 | 9.2 | 0.0074 | 0.150 | 0.08 | 17.1% | 0.026 | 0.0020 | 0.2 | 0.0 | 0.1 |
| | GM_A016_9000234025L01 | 1.72 | 1.37 | 59.6 | 59.6 | 0.0059 | 0.150 | 0.08 | 17.8% | 0.027 | 0.0021 | 1.1 | 0.1 | 0.9 |
| | GM_A016_9000234045L01 | 0.12 | 0.11 | 4.9 | 4.9 | 0.0016 | 0.225 | 0.11 | 30.4% | 0.068 | 0.0102 | 0.2 | 0.0 | 0.1 |
| 2021 Post-develop. | GM_A016_9000100916L01 | 0.62 | 0.43 | 59.2 | 59.2 | 0.0033 | 0.225 | 0.11 | 23.4% | 0.053 | 0.0071 | 2.4 | 0.4 | 1.9 |
| | GM_A016_9000101219L01 | 2.89 | 2.70 | 41.6 | - 195.2 | 0.0046 | 0.150 | 0.08 | 32.4% | 0.049 | 0.0050 | - 3.4 | - 1.0 | - |
| | GM_A016_9000101222L01 | 3.59 | 2.89 | 58.5 | - 90.4 | 0.0120 | 0.150 | 0.08 | 30.4% | 0.046 | 0.0045 | - 1.6 | - 0.4 | - |
| | GM_A016_9000101241L01 | 0.27 | 0.19 | 33.5 | 33.5 | 0.0024 | 0.225 | 0.11 | 28.2% | 0.063 | 0.0092 | 1.3 | 0.3 | 1.0 |
| | GM_A016_9000101247L01 | 0.86 | 0.62 | 70.0 | 70.0 | 0.0033 | 0.225 | 0.11 | 23.5% | 0.053 | 0.0071 | 2.8 | 0.5 | 2.3 |
| | GM_A016_9000154951L01 | 0.35 | 0.33 | 92.7 | 92.7 | 0.0002 | 0.300 | 0.15 | 25.9% | 0.078 | 0.0145 | 6.5 | 1.3 | 5.2 |
| | GM_A016_9000155308L01 | 0.15 | 0.12 | 19.6 | 19.6 | 0.0016 | 0.300 | 0.15 | 27.6% | 0.083 | 0.0159 | 1.4 | 0.3 | 1.1 |
| | GM_A016_9000233697L01 | 0.43 | 0.35 | 23.3 | 23.3 | 0.0033 | 0.300 | 0.15 | 24.1% | 0.072 | 0.0132 | 1.6 | 0.3 | 1.3 |
| | GM_A016_9000233921L01 | 0.33 | 0.31 | 6.5 | 6.5 | 0.0031 | 0.300 | 0.15 | 17.9% | 0.054 | 0.0086 | 0.5 | 0.1 | 0.4 |
| | GM_A016_9000233993L01 | 2.69 | 2.22 | 64.0 | - 56.1 | 0.0073 | 0.150 | 0.08 | 30.1% | 0.045 | 0.0045 | - 1.0 | - 0.3 | - |
| | GM_A016_9000234021L01 | 2.09 | 1.74 | 47.2 | 9.2 | 0.0074 | 0.150 | 0.08 | 31.3% | 0.047 | 0.0047 | 0.2 | 0.0 | 0.1 |
| | GM_A016_9000234025L01 | 1.72 | 1.37 | 59.6 | 59.6 | 0.0059 | 0.150 | 0.08 | 32.6% | 0.049 | 0.0050 | 1.1 | 0.3 | 0.8 |
| | GM_A016_9000234045L01 | 0.12 | 0.11 | 4.9 | 4.9 | 0.0016 | 0.225 | 0.11 | 35.7% | 0.080 | 0.0127 | 0.2 | 0.1 | 0.1 |
| 2066 Pre-develop. | GM_A016_9000100916L01 | 0.62 | 0.43 | 59.2 | 59.2 | 0.0033 | 0.225 | 0.11 | 19.3% | 0.043 | 0.0054 | 2.4 | 0.3 | 2.0 |
| | GM_A016_9000101219L01 | 2.89 | 2.70 | 41.6 | - 195.2 | 0.0046 | 0.150 | 0.08 | 19.4% | 0.029 | 0.0024 | - 3.4 | - 0.5 | - |
| | GM_A016_9000101222L01 | 3.59 | 2.89 | 58.5 | - 90.4 | 0.0120 | 0.150 | 0.08 | 17.8% | 0.027 | 0.0021 | - 1.6 | - 0.2 | - |
| | GM_A016_9000101241L01 | 0.27 | 0.19 | 33.5 | 33.5 | 0.0024 | 0.225 | 0.11 | 25.5% | 0.057 | 0.0080 | 1.3 | 0.3 | 1.1 |
| | GM_A016_9000101247L01 | 0.86 | 0.62 | 70.0 | 70.0 | 0.0033 | 0.225 | 0.11 | 18.3% | 0.041 | 0.0050 | 2.8 | 0.3 | 2.4 |
| | GM_A016_9000154951L01 | 0.35 | 0.33 | 92.7 | 92.7 | 0.0002 | 0.300 | 0.15 | 22.4% | 0.067 | 0.0118 | 6.5 | 1.1 | 5.5 |
| | GM_A016_9000155308L01 | 0.15 | 0.12 | 19.6 | 19.6 | 0.0016 | 0.300 | 0.15 | 27.6% | 0.083 | 0.0159 | 1.4 | 0.3 | 1.1 |
| | GM_A016_9000233697L01 | 0.43 | 0.35 | 23.3 | 23.3 | 0.0033 | 0.300 | 0.15 | 20.2% | 0.061 | 0.0102 | 1.6 | 0.2 | 1.4 |
| | GM_A016_9000233921L01 | 0.33 | 0.31 | 6.5 | 6.5 | 0.0031 | 0.300 | 0.15 | 16.1% | 0.048 | 0.0074 | 0.5 | 0.0 | 0.4 |
| | GM_A016_9000233993L01 | 2.69 | 2.22 | 64.0 | - 56.1 | 0.0073 | 0.150 | 0.08 | 19.7% | 0.030 | 0.0025 | - 1.0 | - 0.1 | - |
| | GM_A016_9000234021L01 | 2.09 | 1.74 | 47.2 | 9.2 | 0.0074 | 0.150 | 0.08 | 22.9% | 0.034 | 0.0030 | 0.2 | 0.0 | 0.1 |
| | GM_A016_9000234025L01 | 1.72 | 1.37 | 59.6 | 59.6 | 0.0059 | 0.150 | 0.08 | 23.8% | 0.036 | 0.0032 | 1.1 | 0.2 | 0.9 |
| | GM_A016_9000234045L01 | 0.12 | 0.11 | 4.9 | 4.9 | 0.0016 | 0.225 | 0.11 | 36.6% | 0.082 | 0.0132 | 0.2 | 0.1 | 0.1 |
| 2066 Post-develop. | GM_A016_9000100916L01 | 0.62 | 0.43 | 59.2 | 59.2 | 0.0033 | 0.225 | 0.11 | 24.9% | 0.056 | 0.0077 | 2.4 | 0.5 | 1.9 |
| | GM_A016_9000101219L01 | 2.89 | 2.70 | 41.6 | - 195.2 | 0.0046 | 0.150 | 0.08 | 31.9% | 0.048 | 0.0049 | - 3.4 | - 0.9 | - |
| | GM_A016_9000101222L01 | 3.59 | 2.89 | 58.5 | - 90.4 | 0.0120 | 0.150 | 0.08 | 29.7% | 0.044 | 0.0044 | - 1.6 | - 0.4 | - |
| | GM_A016_9000101241L01 | 0.27 | 0.19 | 33.5 | 33.5 | 0.0024 | 0.225 | 0.11 | 30.5% | 0.069 | 0.0103 | 1.3 | 0.3 | 1.0 |
| | GM_A016_9000101247L01 | 0.86 | 0.62 | 70.0 | 70.0 | 0.0033 | 0.225 | 0.11 | 24.7% | 0.056 | 0.0077 | 2.8 | 0.5 | 2.2 |
| | GM_A016_9000154951L01 | 0.35 | 0.33 | 92.7 | 92.7 | 0.0002 | 0.300 | 0.15 | 27.6% | 0.083 | 0.0159 | 6.5 | 1.5 | 5.1 |
| | GM_A016_9000155308L01 | 0.15 | 0.12 | 19.6 | 19.6 | 0.0016 | 0.300 | 0.15 | 31.1% | 0.093 | 0.0187 | 1.4 | 0.4 | 1.0 |
| | GM_A016_9000233697L01 | 0.43 | 0.35 | 23.3 | 23.3 | 0.0033 | 0.300 | 0.15 | 25.7% | 0.077 | 0.0143 | 1.6 | 0.3 | 1.3 |
| | GM_A016_9000233921L01 | 0.33 | 0.31 | 6.5 | 6.5 | 0.0031 | 0.300 | 0.15 | 19.4% | 0.058 | 0.0096 | 0.5 | 0.1 | 0.4 |
| | GM_A016_9000233993L01 | 2.69 | 2.22 | 64.0 | - 56.1 | 0.0073 | 0.150 | 0.08 | 30.3% | 0.046 | 0.0045 | - 1.0 | - 0.3 | - |
| | GM_A016_9000234021L01 | 2.09 | 1.74 | 47.2 | 9.2 | 0.0074 | 0.150 | 0.08 | 32.6% | 0.049 | 0.0050 | 0.2 | 0.0 | 0.1 |
| | GM_A016_9000234025L01 | 1.72 | 1.37 | 59.6 | 59.6 | 0.0059 | 0.150 | 0.08 | 34.0% | 0.051 | 0.0053 | 1.1 | 0.3 | 0.7 |
| | GM_A016_9000234045L01 | 0.12 | 0.11 | 4.9 | 4.9 | 0.0016 | 0.225 | 0.11 | 40.1% | 0.090 | 0.0149 | 0.2 | 0.1 | 0.1 |

| | 2021 | 2026 | 2031 | 2036 | 2041 | 2066 |
|----------------------|-------|-------|-------|-------|-------|-------|
| LGIP ES Avail. (kL) | 116.7 | 116.2 | 115.5 | 115.3 | 115.0 | 114.1 |
| LGIP ES Upgrade (kL) | - | - | - | - | - | - |
| ES Storage Lost (kL) | 1.55 | 1.55 | 1.55 | 1.55 | 1.55 | 1.10 |
| ES Req. (kL) | 102.8 | 105.9 | 111.3 | 114.2 | 117.1 | 129.1 |
| Difference (kL) | 12.4 | 8.7 | 2.7 | 0.4 | 3.6 | 16.1 |
| Pass/Fail | PASS | PASS | PASS | FAIL | FAIL | FAIL |

Appendix 9. Water supply standard flow and fire flow modelling results

Standard Flow

| | 2021 | | 2026 | | 2031 | | 2036 | | 2041 | | 2066 | |
|---|-------------------------|--------------|---------------|--------------|---------------|--------------|---------------|--------------|---------------|--------------|---------------|--------------|
| Provision | Post-develop. | Pre-develop. | Post-develop. | Pre-develop. | Post-develop. | Pre-develop. | Post-develop. | Pre-develop. | Post-develop. | Pre-develop. | Post-develop. | Pre-develop. |
| Conn. (MO_11100069906_WTFT) min. pressure (m) | 62.4 | 62.8 | 62.4 | 62.6 | 60.9 | 62.3 | 59.4 | 60.8 | 57.0 | 58.5 | 51.2 | 52.2 |
| Network min. pressure (m) | 38.8 | 39.1 | 38.5 | 38.6 | 36.9 | 38.3 | 35.3 | 36.7 | 33.0 | 34.4 | 27.3 | 28.3 |
| Network no. failures | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Min. pressure node ID | MO_11100320898_WTFT | | | | | | | | | | | |
| Tank min. water level (%) | 80% | 80% | 82% | 82% | 77% | 77% | 72% | 72% | 62% | 61% | 48% | 47% |
| Max. pipe velocity (m/s) | 0.8 | 0.8 | 1.0 | 1.0 | 1.0 | 1.0 | 1.0 | 1.0 | 1.0 | 1.0 | 1.0 | 1.0 |
| Network no. failures | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Network max. velocity ID | MO_9546PIPE_11100057795 | | | | | | | | | | | |

Note: Peak hour occurred at 7 am across all planning horizons.

Fire Flow

| | | 2021 | | 2026 | | 2031 | | 2036 | | 2041 | | 2066 | |
|---------------|---|---------------------|--------------|---------------|--------------|---------------|--------------|---------------|--------------|---------------|--------------|---------------|--------------|
| | Scenario | Post-develop. | Pre-develop. | Post-develop. | Pre-develop. | Post-develop. | Pre-develop. | Post-develop. | Pre-develop. | Post-develop. | Pre-develop. | Post-develop. | Pre-develop. |
| Peak Hour | Site hyd. (MO_11100075453_WTHY) min. pressure (m) | 56.2 | 58.3 | 52.5 | 54.7 | 50.6 | 52.8 | 49.1 | 51.3 | 47.5 | 49.7 | 43.3 | 45.0 |
| | Network hydrant min. pressure (m) | 12.2 | 13.1 | 5.0 | 6.7 | 2.8 | 4.5 | 1.3 | 3.0 | -0.4 | 1.3 | -3.1 | -1.8 |
| | Network hydrant no. failures | 0 | 0 | 0 | 0 | 1 | 0 | 1 | 1 | 2 | 1 | 2 | 2 |
| | Min. pressure node ID | MO_11100067480_WTHY | | | | | | | | | | | |
| 2/3 Peak Hour | Site hyd. (DEM_NODE_HY) min. pressure (m) | 60.7 | 62.1 | 59.0 | 61.0 | 57.8 | 59.4 | 56.6 | 58.2 | 55.0 | 56.6 | 51.2 | 52.5 |
| | Network hydrant min. pressure (m) | 16.4 | 16.5 | 13.8 | 14.0 | 13.6 | 13.6 | 12.4 | 13.5 | 10.8 | 12.0 | 7.9 | 8.8 |
| | Network hydrants no. failures | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 1 | 1 | 1 | 1 |
| | Min. pressure node ID | MO_11100067480_WTHY | | | | | | | | | | | |

Note 1: Results do not consider MOL (15%) of the supply tanks, as the Benowa Rd PRV operates as a “break of head”.

Note 2: Peak hour occurred at 7 am and 2/3 peak hour at 6:30 pm across all planning horizons.